

# City of Austin Water Quality Laboratory

## Drinking Water Quality Report

Samples Collected Between 02/01/2024 - 02/29/2024

Parameter	Units				Davis WTP			Ullrich WTP			Handcox WTP
pH	SU	Avg	9.6	Avg	9.6	Avg	9.6				
		Max	9.8	Max	9.8	Max	9.6				
		Min	9.5	Min	9.5	Min	9.5				
Total Alkalinity	mg/L as CaCO3	Avg	64	Avg	65	Avg	87				
		Max	74	Max	71	Max	90				
		Min	52	Min	62	Min	85				
Total Hardness	mg/L as CaCO3	Avg	113	Avg	116	Avg	118				
		Max	122	Max	121	Max	122				
		Min	102	Min	114	Min	116				
Total Solids	mg/L	Avg	243	Avg	269	Avg	240				
		Max	266	Max	280	Max	254				
		Min	230	Min	262	Min	230				
Total Chloramines	mg/L	Avg	2.65	Avg	2.60	Avg	2.63				
		Max	2.95	Max	2.75	Max	2.78				
		Min	2.30	Min	2.15	Min	2.45				
Total Organic Carbon	mg/L	Avg	2.76	Avg	2.71	Avg	2.88				
		Max	3.02	Max	2.78	Max	2.88				
		Min	2.40	Min	2.62	Min	2.87				
Conductivity	umhos/cm	Avg	416	Avg	405	Avg	431				
		Max	419	Max	405	Max	431				
		Min	412	Min	405	Min	431				
Total Trihalomethanes	ug/L	Avg	33.4	Avg	33.4	Avg	28.3				
		Max	37.2	Max	33.4	Max	28.3				
		Min	29.6	Min	33.4	Min	28.3				
Turbidity	NTU	Avg	.06	Avg	.03	Avg	.05				
		Max	.09	Max	.06	Max	.09				
		Min	.03	Min	.02	Min	.02				