

# City of Austin Water Quality Laboratory

## Drinking Water Quality Report

Samples Collected Between 03/01/2024 - 03/31/2024

Parameter	Units	Davis WTP			Ullrich WTP		Handcox WTP	
pH	SU	Avg	9.7	Avg	9.7	Avg	9.6	
		Max	9.7	Max	9.8	Max	9.7	
		Min	9.6	Min	9.6	Min	9.5	
Total Alkalinity	mg/L as CaCO3	Avg	55	Avg	64	Avg	82	
		Max	62	Max	68	Max	88	
		Min	50	Min	58	Min	78	
Total Hardness	mg/L as CaCO3	Avg	103	Avg	113	Avg	113	
		Max	111	Max	118	Max	120	
		Min	96	Min	106	Min	110	
Total Solids	mg/L	Avg	218	Avg	264	Avg	234	
		Max	236	Max	292	Max	256	
		Min	198	Min	232	Min	208	
Total Chloramines	mg/L	Avg	2.80	Avg	2.67	Avg	2.60	
		Max	2.95	Max	2.75	Max	2.80	
		Min	2.70	Min	2.55	Min	2.45	
Total Organic Carbon	mg/L	Avg	2.55	Avg	2.61	Avg	2.74	
		Max	2.75	Max	2.71	Max	2.79	
		Min	2.38	Min	2.54	Min	2.70	
Conductivity	umhos/cm	Avg	405	Avg	419	Avg	438	
		Max	412	Max	419	Max	438	
		Min	398	Min	419	Min	438	
Total Trihalomethanes	ug/L	Avg	34.0	Avg	35.9	Avg	26.8	
		Max	35.7	Max	35.9	Max	26.8	
		Min	32.3	Min	35.9	Min	26.8	
Turbidity	NTU	Avg	.04	Avg	.02	Avg	.03	
		Max	.06	Max	.05	Max	.04	
		Min	.03	Min	.02	Min	.02	