

City of Austin Water Quality Laboratory

Drinking Water Quality Report

Samples Collected Between 07/01/2023 - 07/31/2023

Parameter	Units	Davis WTP			Ullrich WTP		Handcox WTP	
pH	SU	Avg	9.8	Avg	9.7	Avg	9.6	
		Max	9.9	Max	9.8	Max	9.7	
		Min	9.8	Min	9.7	Min	9.6	
Total Alkalinity	mg/L as CaCO3	Avg	53	Avg	57	Avg	68	
		Max	58	Max	58	Max	72	
		Min	46	Min	56	Min	61	
Total Hardness	mg/L as CaCO3	Avg	85	Avg	89	Avg	96	
		Max	89	Max	90	Max	99	
		Min	78	Min	88	Min	88	
Total Solids	mg/L	Avg	192	Avg	227	Avg	218	
		Max	218	Max	238	Max	232	
		Min	162	Min	212	Min	190	
Total Chloramines	mg/L	Avg	2.72	Avg	2.49	Avg	2.69	
		Max	3.05	Max	2.80	Max	2.90	
		Min	2.55	Min	2.30	Min	2.50	
Total Organic Carbon	mg/L	Avg	2.69	Avg	2.57	Avg	2.72	
		Max	2.83	Max	2.65	Max	2.81	
		Min	2.42	Min	2.52	Min	2.67	
Conductivity	umhos/cm	Avg	338	Avg	349	Avg	391	
		Max	341	Max	349	Max	391	
		Min	334	Min	349	Min	391	
Total Trihalomethanes	ug/L	Avg	33.7	Avg	32.7	Avg	29.2	
		Max	36.0	Max	32.7	Max	29.2	
		Min	31.4	Min	32.7	Min	29.2	
Turbidity	NTU	Avg	.06	Avg	.02	Avg	.03	
		Max	.10	Max	.04	Max	.08	
		Min	.04	Min	.02	Min	.02	