

City of Austin Water Quality Laboratory

Drinking Water Quality Report

Samples Collected Between 10/01/2022 - 10/31/2022

Parameter	Units	Davis WTP		Ullrich WTP		Handcox WTP	
pH	SU	Avg	9.7	Avg	9.7	Avg	9.7
		Max	9.8	Max	9.9	Max	9.7
		Min	9.6	Min	9.6	Min	9.6
Total Alkalinity	mg/L as CaCO3	Avg	59	Avg	67	Avg	72
		Max	66	Max	72	Max	78
		Min	49	Min	56	Min	66
Total Hardness	mg/L as CaCO3	Avg	89	Avg	95	Avg	97
		Max	96	Max	100	Max	103
		Min	80	Min	84	Min	91
Total Solids	mg/L	Avg	194	Avg	228	Avg	213
		Max	242	Max	240	Max	234
		Min	158	Min	206	Min	192
Total Chloramines	mg/L	Avg	2.77	Avg	2.68	Avg	2.70
		Max	2.95	Max	2.90	Max	2.90
		Min	2.60	Min	2.45	Min	2.50
Total Organic Carbon	mg/L	Avg	2.54	Avg	2.46	Avg	2.47
		Max	2.74	Max	2.58	Max	2.51
		Min	2.22	Min	2.32	Min	2.44
Conductivity	umhos/cm	Avg	302	Avg	338	Avg	365
		Max	306	Max	338	Max	365
		Min	297	Min	338	Min	365
Total Trihalomethanes	ug/L	Avg	31.5	Avg	23.4	Avg	22.5
		Max	32.7	Max	23.4	Max	22.5
		Min	30.3	Min	23.4	Min	22.5
Turbidity	NTU	Avg	.05	Avg	.03	Avg	.05
		Max	.07	Max	.06	Max	.07
		Min	.03	Min	.02	Min	.04