

City of Austin Water Quality Laboratory

Drinking Water Quality Report

Samples Collected Between 9/1/2020 - 9/30/2020

Parameter	Units		Davis WTP		Ullrich WTP		Handcox WTP
pH	SU	Avg	9.7	Avg	9.65	Avg	9.7
		Max	9.7	Max	9.87	Max	9.7
		Min	9.6	Min	9.44	Min	9.6
Total Alkalinity	mg/L as CaCO3	Avg	60	Avg	55	Avg	64
		Max	69	Max	61	Max	68
		Min	56	Min	52	Min	61
Total Hardness	mg/L as CaCO3	Avg	88	Avg	84	Avg	88
		Max	95	Max	90	Max	92
		Min	83	Min	81	Min	85
Total Chloramines	mg/L	Avg	2.89	Avg	2.66	Avg	2.82
		Max	2.98	Max	2.88	Max	2.95
		Min	2.80	Min	2.40	Min	2.55
Total Organic Carbon	mg/L	Avg	2.56	Avg	2.32	Avg	2.42
		Max	3.40	Max	2.85	Max	3.32
		Min	2.35	Min	2.10	Min	2.17
Total Trihalomethanes	ug/L	Avg	34.6	Avg	37.3	Avg	26.3
		Max	35.4	Max	37.3	Max	26.3
		Min	33.7	Min	37.3	Min	26.3
Turbidity	NTU	Avg	0.06	Avg	0.02	Avg	0.03
		Max	0.14	Max	0.03	Max	0.05
		Min	0.04	Min	0.01	Min	0.02

Due to Covid-19 the number of parameters analyzed has been reduced effective 3-27-20.