

City of Austin Water Quality Laboratory

Drinking Water Quality Report

Samples Collected Between 11/01/2021 - 11/30/2021

Parameter	Units	Davis WTP			Ullrich WTP		Handcox WTP	
pH	SU	Avg	9.7	Avg	9.7	Avg	9.6	
		Max	9.8	Max	9.8	Max	9.7	
		Min	9.6	Min	9.6	Min	9.6	
Total Alkalinity	mg/L as CaCO3	Avg	55	Avg	59	Avg	70	
		Max	59	Max	62	Max	72	
		Min	50	Min	54	Min	67	
Total Hardness	mg/L as CaCO3	Avg	89	Avg	94	Avg	96	
		Max	96	Max	100	Max	99	
		Min	82	Min	90	Min	92	
Total Solids	mg/L	Avg	178	Avg	184	Avg	193	
		Max	196	Max	200	Max	214	
		Min	166	Min	172	Min	186	
Total Chloramines	mg/L	Avg	2.83	Avg	2.76	Avg	2.48	
		Max	2.90	Max	2.85	Max	2.65	
		Min	2.75	Min	2.65	Min	2.25	
Total Organic Carbon	mg/L	Avg	2.47	Avg	2.47	Avg	2.30	
		Max	2.63	Max	2.60	Max	2.34	
		Min	2.32	Min	2.38	Min	2.24	
Conductivity	umhos/cm	Avg	307	Avg	320	Avg	348	
		Max	308	Max	320	Max	348	
		Min	306	Min	320	Min	348	
Total Trihalomethanes	ug/L	Avg	48.0	Avg	37.9	Avg	23.0	
		Max	50.4	Max	37.9	Max	23.0	
		Min	45.6	Min	37.9	Min	23.0	
Turbidity	NTU	Avg	.07	Avg	.04	Avg	.04	
		Max	.09	Max	.12	Max	.09	
		Min	.05	Min	.02	Min	.02	